

Zhutnitelnost

A. č.: CD6 / L / 006 / 3

Metoda : A

Zakázka : HLUK - RD v lokalitě " Pod Sádka " "

Číslo vzorku 4842

Sonda V - 7

Hloubka 1.0 m

Měření	Hmoždír Objem hmot. [%] [g]	Vlhká zemina [g]	Miska hmot. [g]	Vlhká zemina s miskou [g]	Suchá zemina s miskou [g]	Vlhkost [%]	Vlhkost průměrná [%]	Suchá zemina [g]	Objemová hmotnost [kg/m3]
1.	1000.0 171.0	2828.0	77.7 79.2	104.3 105.6	100.7 101.9	15.4 16.0	15.7	1432.2	1432.2
2.	1000.0 171.0	2952.0	79.4 78.5	116.6 118.5	110.8 111.8	18.4 20.2	19.3	1493.1	1493.1
3.	1000.0 171.0	3049.0	79.6 77.4	124.2 116.4	115.9 109.7	22.9 20.9	21.9	1541.0	1541.0
4.	1000.0 171.0	3079.0	80.5 79.7	150.9 143.0	136.2 129.6	26.4 26.9	26.7	1506.5	1506.5

— S = 1.00

W_{opt} = 23.06 %

D = 0.00

- - - S = 0.90

ρ_{dmax} = 1547.75

ρ_D = 0

Objemová hmotnost [kg/m3]

